



2021/22 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	37	Region	
SD Name	Delta	Contact Name	
SD Contact Name:	Mel Gomez	Contact Phone	
SD Contact Phone:	604-841-0116	Report Submitted to HA	
Report Date	24-Mar-22	Report Submission Date	

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION			
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
37	3737009	Annieville Elementary	1956	03/2022	1	Water Fountain	Rm 120	0.002	No				03/2025	30-Mar-22
37	3737009	Annieville Elementary	1956	03/2022	1	Sink	KG 122	0.000	No				03/2025	30-Mar-22
37	3737009	Annieville Elementary	1956	03/2022	1	Sink	KG 123	0.001	No				03/2025	30-Mar-22
37	3737009	Annieville Elementary	1956	03/2022	1	Water Filling Station	Rm 006	0.000	No				03/2025	30-Mar-22
37	3737009	Annieville Elementary	1956	03/2022	1	Water Fountain	Rm 104	0.021	Yes			Decommissioned - will replace the unit and the piping this summer break.	03/2025	30-Mar-22
37	3737009	Annieville Elementary	1956	03/2022	1	Sink	Staff Room 151	0.001	No				03/2025	30-Mar-22
37	3737009	Annieville Elementary	1956	03/2022	1	Water Filling Station	Rm 148	0.001	No				03/2025	30-Mar-22
37	3737029	Brooke Elementary	1972	03/2022	1	Sink	Staff Room 142	0.000	No				03/2025	30-Mar-22
37	3737029	Brooke Elementary	1972	03/2022	1	Water Fountain	Room 132B	0.001	No				03/2025	30-Mar-22
37	3737029	Brooke Elementary	1972	03/2022	1	Water Filling Station	Rm 131A	0.002	No				03/2025	30-Mar-22
37	3737029	Brooke Elementary	1972	03/2022	1	Water Filling Station	Rm 137A	0.001	No				03/2025	30-Mar-22
37	3737029	Brooke Elementary	1972	03/2022	1	Water Fountain	Rm 127	0.001	No				03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Sink	Staff Room 136	0.001	No				03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Water Filling Station	Rm 135A	0.000	No				03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Water Filling Station	Rm 167	0.000	No				03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Water Fountain	Rm 121	0.007	Yes			Decommissioned - will replace the unit and the piping this summer break.	03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Water Filling Station	Rm 126	0.000	No				03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	2	Water Fountain	Rm 148	0.002	No			Test 1 (.0088) Test 2 (.0017)	03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Water Filling Station	Rm 108C	0.000	No				03/2025	30-Mar-22
37	3737034	Burnsview Secondary	1972	03/2022	1	Water Fountain	Room 204B Sink	0.017	Yes			Decommissioned - Will replace the piping this summer break.	03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Sink	Staff Room 101	0.000	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Filling Station	Rm 109	0.001	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Fountain	Rm 135	0.000	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Filling Station	Rm 119	0.000	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Fountain	Rm 111	0.002	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Filling Station	Rm 137	0.000	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Fountain	Rm 150	0.004	No				03/2025	30-Mar-22
37	3737022	Chalmers Elementary	1973	03/2022	1	Water Fountain	Rm 146	0.000	No				03/2025	30-Mar-22
37	3737039	Cougar Canyon Elementary	1980	03/2022	1	Sink	Staff Rm 141	0.001	No				03/2025	30-Mar-22
37	3737039	Cougar Canyon Elementary	1980	03/2022	1	Water Filling Station	Rm 139	0.001	No				03/2025	30-Mar-22
37	3737039	Cougar Canyon Elementary	1980	03/2022	1	Water Filling Station	Rm 106	0.001	No				03/2025	30-Mar-22
37	3737039	Cougar Canyon Elementary	1980	03/2022	1	Water Filling Station	Rm 124	0.000	No				03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Sink	Staff Room 105	0.000	No				03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Water Filling Station	Rm 102	0.001	No				03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Water Filling Station	Rm 108	0.017	Yes			Decommissioned - Will replace the piping this summer break.	03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Water Filling Station	Rm 124	0.004	No				03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Water Fountain	Rm 129	0.009	Yes			Removed not needed	03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Sink	Food Rm 126	0.001	No				03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Water Filling Station	Rm 181	0.001	No				03/2025	30-Mar-22
37	3737021	Delview Secondary	1969	03/2022	1	Water Filling Station	Rm 148	0.000	No				03/2025	30-Mar-22
37	3737017	Devon Gardens Elementary	1963	03/2022	1	Water Filling Station	Rm 107	0.002	No				03/2025	30-Mar-22
37	3737017	Devon Gardens Elementary	1963	03/2022	1	Water Filling Station	Rm 134	0.000	No				03/2025	30-Mar-22
37	3737017	Devon Gardens Elementary	1963	03/2022	1	Sink	Staff Rm 215	0.000	No				03/2025	30-Mar-22
37	3737017	Devon Gardens Elementary	1963	03/2022	2	Water Fountain	Rm 201	0.001	No			Test 1 (.0058) Test 2 (.00089)	03/2025	30-Mar-22
37	3737017	Devon Gardens Elementary	1963	03/2022	1	Water Filling Station	Rm 205	0.001	No				03/2025	30-Mar-22
37	3737026	Gibson Elementary	1971	03/2022	1	Water Fountain	Staff Rm 136	0.000	No				03/2025	30-Mar-22
37	3737026	Gibson Elementary	1971	03/2022	1	Water Filling Station	Rm 154	0.000	No				03/2025	30-Mar-22
37	3737026	Gibson Elementary	1971	03/2022	1	Water Filling Station	Rm 143	0.001	No				03/2025	30-Mar-22
37	3737026	Gibson Elementary	1971	03/2022	1	Water Fountain	Rm 114	0.015	Yes			Decommissioned - will replace the unit and the piping this summer break.	03/2025	30-Mar-22
37	3737026	Gibson Elementary	1971	03/2022	1	Water Filling Station	Rm 111B	0.000	No				03/2025	30-Mar-22
37	3737026	Gibson Elementary	1971	03/2022	1	Water Fountain	Rm 105C	0.003	No				03/2025	30-Mar-22