



School District Information	
SD No.	37
SD Name	Delta
SD Contact Name:	Mel Gomez
SD Contact Phone:	604-841-0116
Report Date	21-Mar-23

SCHOOL FACILITY INFORMATION				MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN					ADDITIONAL INFORMATION				
Ministry Facility Code	School Facility Name	Year Built	Date of Test (dd-mm-yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Ministry Submission Period	Next Scheduled Date of Testing (dd-mm-yyyy)
3737030	Jarvis Elementary	1972	28/02/2023	1	Sink	Staff Room 134	0.000	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Drinking Fountain	Changeroom 128	0.000	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Drinking Fountain	Changeroom 129	0.000	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 126	0.001	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 126	0.003	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Water Filling Station	Corridor 137	0.000	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Water Filling Station	Corridor 121	0.000	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Water Filling Station	Corridor 116	0.001	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 110	0.000	No				30/03/2023	01/03/2026
3737030	Jarvis Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 105	0.000	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Sink	Staff Room 135	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 112 by Room 154	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Water Filling Station	Classroom 112	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor by Room 127A	0.000	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 122	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 147	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 110	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor 105	0.000	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Corridor by Room 127 C	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Changeroom 130	0.001	No				30/03/2023	01/03/2026
3737032	McCloskey Elementary	1972	28/02/2023	1	Drinking Fountain	Changeroom 131	0.001	No				30/03/2023	01/03/2026
3737012	North Delta Secondary	1957	28/02/2023	1	Sink	Staff Room 1210	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Water Filling Station	Corridor 1220	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Water Filling Station	Corridor 1513	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Drinking Fountain	Classroom 1500	0.003	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Sink	Kitchen 1512	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Sink	Foods Room 1604	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Water Filling Station	Corridor 2313	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Drinking Fountain	Corridor 2004					Decommissioned - Removed the unit	30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Water Filling Station	Corridor 1003	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Drinking Fountain	Corridor 0022	0.000	No				30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Drinking Fountain	Changeroom 1408					Decommissioned - Removed the unit	30/03/2023	01/03/2020
3737012	North Delta Secondary	1957	28/02/2023	1	Drinking Fountain	Changeroom 1409	0.000	No				30/03/2023	01/03/2020
3737041	Pinewood Elementary	1981	28/02/2023	1	Drinking Fountain	Corridor 154 by Room 127	0.000	No				30/03/2023	01/03/2020
3737041	Pinewood Elementary	1981	28/02/2023	1	Drinking Fountain	Corridor 159 by Room 155	0.000	No				30/03/2023	01/03/2020
3737041	Pinewood Elementary	1981	28/02/2023	1	Drinking Fountain	Changeroom 152	0.006	yes			Decommissioned - Will replace the piping this summer break	30/03/2023	01/03/2020
3737041	Pinewood Elementary	1981	28/02/2023	1	Sink	Staff Room 116	0.000	No				30/03/2023	01/03/2020
3737041	Pinewood Elementary	1981	28/02/2023	1	Drinking Fountain	Changeroom 151	0.000	No				30/03/2023	01/03/2020
3737041	Pinewood Elementary	1981	28/02/2023	1	Water Filling Station	Corridor 100 by Room 158	0.000	No				30/03/2023	01/03/2020
3737007	Richardson Elementary	1951	28/02/2023	1	Drinking Fountain	Corridor 102 by Room 127	0.000	No				30/03/2023	01/03/2020
3737007	Richardson Elementary	1951	28/02/2023	1	Sink	Staff Room 109	0.000	No				30/03/2023	01/03/2020
3737007	Richardson Elementary	1951	28/02/2023	1	Water Filling Station	Corridor 201 by Room 211	0.000	No				30/03/2023	01/03/2020
3737007	Richardson Elementary	1951	28/02/2023	1	Water Filling Station	Corridor 131 by Room 137	0.000	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Sink	Staff Room 512	0.000	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Sink	Foods Room 310	0.001	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Water Filling Station	Corridor 500 by Room 209	0.000	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Water Filling Station	Corridor 601 by Room 605	0.000	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Water Filling Station	Corridor 500 by Room 302	0.000	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Water Filling Station	Corridor 500 by Room 312	0.000	No				30/03/2023	01/03/2020
3737038	Sands Secondary	1974	28/02/2023	1	Drinking Fountain	Corridor 500 by Room 401	0.000	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	1	Sink	Staff Room 1108	0.000	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	2	Sink	Kitchen 1116	0.000	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	3	Water Filling Station	Corridor 1014 Opposite Elevator	0.002	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	4	Sink	Foods Room 1403	0.000	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	5	Water Filling Station	Corridor 1400 by Room 1403	0.000	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	6	Water Filling Station	Corridor 1400 by room 1407	0.001	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	7	Drinking Fountain	Corridor 1400 by Room 1429	0.002	No				30/03/2023	01/03/2020
3737040	Seaquam Secondary	1977	28/02/2023	8	Water Filling Station	Corridor 1400 by Room 1423	0.000	No				30/03/2023	01/03/2020

