

School District Information

Health Authority (HA) Information

37	Region
Delta	Contact Name
Mel Gomez	Contact Phone
604-841-0116	Report Submitted to HA
2/29/2024	Report Submission Date

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY		ADDITIONAL INFORMATION			
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
37	3737019	Beach Grove Elementary	1967	Feb-24	1	Sink	Staff Room 8	0.000					02/2027	28-Feb-24
37	3737019	Beach Grove Elementary	1967	Feb-24	1	Water Filling Station	Corridor 50 (Near Room 02)	0.000					02/2027	28-Feb-24
37	3737019	Beach Grove Elementary	1967	Feb-24	1	Water Fountain	Corridor 60 (Near Gym 50)	0.001					02/2027	28-Feb-24
37	3737019	Beach Grove Elementary	1967	Feb-24	1	Water Filling Station	Corridor 60 (Near Room 19)	0.000					02/2027	28-Feb-24
	3737019	Beach Grove Elementary	1967	Feb-24	1	Sink	Medical Room 35	0.000					02/2027	28-Feb-24
	3737019	Beach Grove Elementary	1967	Feb-24	1	Sink	Room 20	0.001					02/2027	28-Feb-24
37	3737019	Beach Grove Elementary	1967	Feb-24	1	Water Fountain	Corridor 60 (Near Room 26)	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Sink	Staff Room 145	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Water Filling Station	Corridor 100	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Drinking Fountain	Corridor 200	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Water Filling Station	Corridor 100	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Water Filling Station	Corridor 200	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Water Filling Station	Corridor 200	0.000					02/2027	28-Feb-24
37	3737015	Cliff Drive Elementary	1962	Feb-24	1	Drinking Fountain	Corridor 200	0.000					02/2027	28-Feb-24
	3737015	Cliff Drive Elementary	1962	Feb-24	1	Sink	Medical Room 101c	0.000					02/2027	28-Feb-24
	3737015	Cliff Drive Elementary	1962	Feb-24	1	Sink	Kitchen Room 137	0.000					02/2027	28-Feb-24
37	3737010	Delta Manor Education Centre	1956	Feb-24	1	Sink	Staff Room 159	0.000					02/2027	28-Feb-24
37	3737010	Delta Manor Education Centre	1956	Feb-24	1	Drinking Fountain	Rm 121	0.000					02/2027	28-Feb-24
	373010	Delta Manor Education Centre	1956	Feb-24	1	Sink	Medical Room	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 2600 (Fountain 2610)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 2700 (Fountain 2712)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 2700 (Fountain 2724)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 2600 (Fountain 2606)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 1600 (Fountain 1635)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 1700 (Fountain 1610)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 1700 (Fountain 1716)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Classroom 2300 (Theatre 2nd Flr)	0.001					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Corridor 1500 (Gym 1808)	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Water Filling Station	Fountain 1603	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Sink	Staff Room 1556	0.000					02/2027	28-Feb-24
37	3737003	Delta Secondary	1926	Feb-24	1	Sink	Medical Room 1574	0.000					02/2027	28-Feb-24
37	3737010	English Bluff Elementary	1962	Feb-24	1	Sink	Staff Room 121	0.000					02/2027	28-Feb-24

37	3737010	English Bluff Elementary	1962	Feb-24	1	Water Filling Station	Corridor 100 (Near Room 119)	0.000	02/2027	28-Feb-24
37	3737010	English Bluff Elementary	1962	Feb-24	1	Water Fountain	Corridor 114 (Near Room 112)	0.001	02/2027	28-Feb-24
37	3737010	English Bluff Elementary	1962	Feb-24	1	Water Filling Station	Corridor 200 (Near Room 219)	0.001	02/2027	28-Feb-24
37	3737010	English Bluff Elementary	1962	Feb-24	1	Sink	Medical Room118	0.001	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Fountain	Changeroom 134 (Fountain 134)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Fountain	Corridor 101 (Fountain 101C)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Filling Station	Corridor 145 (Fountain 145)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Fountain	Corridor 109 (Fountain 109C)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Filling Station	Corridor 116A (Fountain 116A)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Fountain	Corridor 121 (Fountain 121D)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Water Fountain	Corridor 126 (Fountain 126)	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Sink	Staff Room 137	0.000	02/2027	28-Feb-24
37	3737025	Hawthorne Elementary	1970	Feb-24	1	Sink	Medical Room 138B	0.000	02/2027	28-Feb-24
37	3737035	Holly Elementary	1973	Feb-24	1	Sink	Staff Room 147	0.000	02/2027	28-Feb-24
37	3737035	Holly Elementary	1973	Feb-24	1	Water Fountain	Corridor 134 (Fountain 134A)	0.001	02/2027	28-Feb-24
37	3737035	Holly Elementary	1973	Feb-24	1	Water Fountain	Corridor 134 (Fountain 134C)	0.000	02/2027	28-Feb-24
37	3737035	Holly Elementary	1973	Feb-24	1	Water Filling Station	Corridor 142 (Fountain 142)	0.000	02/2027	28-Feb-24
37	3737035	Holly Elementary	1973	Feb-24	1	Water Fountain	Corridor 133 (Fountain 133C)	0.000	02/2027	28-Feb-24
37	3737035	Holly Elementary	1973	Feb-24	1	Water Fountain	Corridor 151 (Fountain 151C)	0.000	02/2027	28-Feb-24
	3737035	Holly Elementary	1973	Feb-24	1	Sink	Medical Room 145A	0.000	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Sink	Staff Room 145	0.000	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Water Filling Station	Corridor 150 (Fountain Gym)	0.001	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Water Filling Station	Corridor 216 (Fountain 205)	0.000	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Water Fountain	Corridor 216 (Fountain 206)	0.001	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Water Fountain	Corridor 134 (Fountain 101)	0.001	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Water Filling Station	Corridor 122 (Fountain 110)	0.000	02/2027	28-Feb-24
37	3737001	Ladner Elementary	1917	Feb-24	1	Water Filling Station	Corridor 121 (Fountain 117)	0.000	02/2027	28-Feb-24
	3737001	Ladner Elementary	1917	Feb-24	1	Sink	Medical Room	0.001	02/2027	28-Feb-24
	3737001	Ladner Elementary	1917	Feb-24	1	Sink	Kitchen Room 157	0.000	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Sink	Staff Room 132	0.000	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Water Fountain	Corridor 115B	0.000	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Water Filling Station	Corridor 100A	0.005	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Water Fountain	Corridor 119C	0.000	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Water Filling Station	Corridor 123	0.000	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Water Filling Station	Changeroom 127	0.000	02/2027	28-Feb-24
37	3737027	Pebble Hill Elementary	1971	Feb-24	1	Water Fountain	Changeroom 128	0.000	02/2027	28-Feb-24
	3737027	Pebble Hill Elementary	1971	Feb-24	1	Sink	Kitchen Room 131	0.000	02/2027	28-Feb-24
	3737037	Pebble Hill Elementary	1971	Feb-24	1	Sink	Medical Room 134	0.000	02/2027	28-Feb-24

