



2024/2025 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

Ministry of Education

School District Information

Health Authority (HA) Information

37	Region
Delta	Contact Name
Mel Gomez	Contact Phone
604-841-0116	Report Submitted to HA
2/28/2025	Report Submission Date

SCHOOL FACILITY INFORMATION					TEST INFORMATION					Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations					
37	3737009	Annieville Elementary	1956	02/2025	1	Water Fountain	Rm 120	0.00048	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Sink	KG 122	0.00005	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Sink	KG 123	0.00005	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Water Filling Station	Rm 006	0.0003	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Water Fountain	Rm 104	0.0004	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Sink	Staff Room 151	0.00007	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Water Filling Station	Rm 207	0.00047	No				02/2028	28-Feb-25
37	3737009	Annieville Elementary	1956	02/2025	1	Water Filling Station	Rm 148	0.00005	No				02/2028	28-Feb-25
37	3737029	Brooke Elementary	1972	02/2025	1	Sink	Staff Room 142	0.00012	No				02/2028	28-Feb-25
37	3737029	Brooke Elementary	1972	02/2025	1	Water Fountain	Room 132B	0.00055	No				02/2028	28-Feb-25
37	3737029	Brooke Elementary	1972	02/2025	1	Water Filling Station	Rm 131A	0.00016	No				02/2028	28-Feb-25
37	3737029	Brooke Elementary	1972	02/2025	1	Water Filling Station	Rm 137A	0.00037	No				02/2028	28-Feb-25
37	3737029	Brooke Elementary	1972	02/2025	1	Water Fountain	Rm 127	0.00008	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Sink	Staff Room 136	0.00011	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Filling Station	Rm 135A	0.00035	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Filling Station	Rm 167	0.00009	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Fountain	Rm 121	0.00067	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Filling Station	Rm 122	0.00006	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Fountain	Rm 148	0.0003	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Filling Station	Rm 108C	0.00009	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Sink	Rm 125	0.00086	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Kitchen Sink	Rm 166	0.00073	No				02/2028	28-Feb-25
37	3737034	Burnsview Secondary	1972	02/2025	1	Water Fountain	Room 204B Sink	0.00033	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Sink	Staff Room 101	0.00009	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Filling Station	Rm 109	0.0002	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Fountain	Rm 135	0.00012	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Filling Station	Rm 119	0.00026	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Fountain	Rm 111	0.00019	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Filling Station	Rm 137	0.00008	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Fountain	Rm 150	0.00081	No				02/2028	28-Feb-25
37	3737022	Chalmers Elementary	1973	02/2025	1	Water Fountain	Rm 146	0.00025	No				02/2028	28-Feb-25
37	3737039	Cougar Canyon Elementary	1980	02/2025	1	Sink	Staff Rm 141	0.00025	No				02/2028	28-Feb-25
37	3737039	Cougar Canyon Elementary	1980	02/2025	1	Water Filling Station	Rm 139	0.00066	No				02/2028	28-Feb-25
37	3737039	Cougar Canyon Elementary	1980	02/2025	1	Water Filling Station	Rm 106	0.00038	No				02/2028	28-Feb-25
37	3737039	Cougar Canyon Elementary	1980	02/2025	1	Water Filling Station	Rm 124	0.00014	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Sink	Staff Room 105	0.00005	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Water Filling Station	Rm 102	0.00065	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Water Filling Station	Rm 108	0.00028	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Water Filling Station	Rm 124	0.00062	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Sink	Food Rm 126	0.00019	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Water Filling Station	Rm 181	0.00062	No				02/2028	28-Feb-25
37	3737021	Delview Secondary	1969	02/2025	1	Water Filling Station	Rm 148	0.00027	No				02/2028	28-Feb-25
37	3737017	Devon Gardens Elementary	1963	02/2025	1	Water Filling Station	Rm 107	0.00039	No				02/2028	28-Feb-25
37	3737017	Devon Gardens Elementary	1963	02/2025	1	Water Filling Station	Rm 134	0.00009	No				02/2028	28-Feb-25
37	3737017	Devon Gardens Elementary	1963	02/2025	1	Sink	Staff Rm 215	0.00023	No				02/2028	28-Feb-25
37	3737017	Devon Gardens Elementary	1963	02/2025	1	Water Fountain	Rm 201	0.0011	No				02/2028	28-Feb-25
37	3737017	Devon Gardens Elementary	1963	02/2025	1	Water Filling Station	Rm 205	0.00024	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Fountain	Staff Rm 136	0.00018	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Filling Station	Rm 154	0.00007	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Filling Station	Rm 143	0.00027	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Fountain	Rm 114	0.00035	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Filling Station	Rm 111B	0.00007	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Fountain	Rm 105C	0.0016	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Fountain	Rm 124A	0.00048	No				02/2028	28-Feb-25
37	3737026	Gibson Elementary	1971	02/2025	1	Water Fountain	Rm 129A	0.00036	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Sink	Staff Rm 110	0.00007	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Fountain	Change Rm 112	0.00052	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Fountain	Change Rm 113	0.00051	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Filling Station	Rm 105	0.00035	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Filling Station	Rm 706	0.00008	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Filling Station	Rm 606	0.00008	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Filling Station	Rm 111	0.00008	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Fountain	Rm 507	0.00087	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Fountain	Rm 303	0.00034	No				02/2028	28-Feb-25
37	3737024	Gray Elementary	1970	02/2025	1	Water Fountain	Rm 205	0.00032	No				02/2028	28-Feb-25
37	3737008	Heath Elementary	1950	02/2025	1	Sink	Staff Rm 129	0.00036	No				02/2028	28-Feb-25
37	3737008	Heath Elementary	1950	02/2025	1	Water Filling Station	Rm 133	0.00015	No				02/2028	28-Feb-25
37	3737008	Heath Elementary	1950	02/2025	1	Water Fountain	Rm 137	0.00027	No				02/2028	28-Feb-25
37	3737008	Heath Elementary	1950	02/2025	1	Water Filling Station	Rm 215	0.00071	No				02/2028	28-Feb-25
37	3737008	Heath Elementary	1950	02/2025	1	Water Fountain	Rm 119	0.00063	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Sink	Staff Rm 136	0.0008	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Filling Station	Rm 152	0.00021	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Filling Station	Rm 142	0.00007	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Fountain	Rm 124C	0.00024	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Filling Station	Rm 118A	0.00015	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Fountain	Rm 111C	0.00076	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Fountain	Change Rm 131	0.00052	No				02/2028	28-Feb-25
37	3737023	Helings Elementary	1970	02/2025	1	Water Fountain	Change Rm 132	0.00077	No				02/2028	28-Feb-25